

SAFETY AND BUILDINGS DIVISION
Plumbing Product Review
P.O. Box 2658
Madison, Wisconsin 53701-2658
TTY: Contact Through Relay
Jim Doyle, Governor
Richard J. Leinenkugel, Secretary

September 30, 2009

REDMAN HOMES INC. CHAMPION HOMES BOBBY CAMPBELL 308 SHERIDIAN DR. TOPEKA IN 46571

Re: Description: PREFABRICATED PLUMBING SYSTEM

Manufacturer: REDMAN HOMES INC.
Product Name: MODULAR RANCH
Model Number(s): RM 01/ RM 02
Product File No: 20090322

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of September 2014.

This approval is contingent upon compliance with the following stipulation(s):

- The flowing water supply pressure at the point(s) of connection must be at least 23 psig.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the
  department's stamp of approval. The plans and specifications must be open to inspection by an authorized
  representative of the department.
- This approval is for only the prefabricated plumbing system as defined herein. "Prefabricated Plumbing" means
  concealed drain piping, vent piping or water supply piping or a combination of these types of piping, contained in
  a modular building component, which will not be visible for inspection when delivered to the final site of
  installation.

A copy of the approved plans and/or specifications is enclosed.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jerry Thompson Plumbing Product Reviewer Phone: 608-266-6742 Fax: 608-267-9566

E-mail: jerry.thompson@wi.gov

SBD-10564-E (N.10/97) File Ref: 09032204.DOC